



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 423

Customer

Facility Name: Nova Care
Address: 1136 J. Thorn Run Rd.
Moon Twp., PA 15108

Sample Collection

Date: 5/4/26
Time: 9:47 AM
Method: Grab

Matrix: Recreational Water

Source Type: Pool

Sample Final Analysis

Date: 5/7/26
Time: 11:00 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/5/26	10:30 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/5/26	10:30 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	5/4/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/4/26	9:47 AM	AMH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/4/26	9:47 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/4/26	9:47 AM	AMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)