



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
W-10

Lab# 020

Customer

Facility Name: Beaver Area HS
Address: Gypsy Glen
Beaver, PA 15009

Sample Collection

Date: 5/26/26
Time: 12:59 PM
Method: Grab

Sample Final Analysis

Date: 5/28/26
Time: 1:30 PM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/27/26 1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/27/26 1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/26/26 5:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/26/26 12:59 PM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/26/26 12:59 PM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/26/26 12:59 PM	AMH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor