# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**
**C-2**

***Lab# 032***

| **Customer** | | **Sample Collection** | |
|---|---|---|---|
| *Facility Name:* | *Cambria Suites* | *Date:* | *3/17/26* |
| | | *Time:* | 10:50 AM |
| *Address:* | *1320 Centre Ave*<br>*Pittsburgh, PA 15219* | *Method:* | *Grab* |
| | | **Sample Final Analysis** | |
| *Matrix:* | *Recreational Water* | *Date:* | *3/20/26* |
| | | *Time:* | *10:30 AM* |
| *Source Type:* | *Spa* | *Analyst:* | *AS* |

| **Accredited Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 3/18/26 | 10:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 3/18/26 | 10:00 AM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 3/17/26 | 2:30 PM | SL | SM 9215B |

| **Additional Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 3/18/26 | 10:30 AM | SL | SM 9230C |

| **Field Analysis** | **Results** | **Reporting limit** | **Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| pH: | 8.0 SU | 7.2 - 7.8 SU | 3/17/26 | 10:50 AM | BH | DPD |
| Chlorine: | 10.0 mg/l | 1.0 - 5.0 mg/l | 3/17/26 | 10:50 AM | BH | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 3/17/26 | 10:50 AM | BH | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)