Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 452

Customer

Facility Name: *Doubletree Cranberry*

Address: *910 Sheraton Dr*
Mars, PA 16046

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *4/1/26*
Time: 11:15 AM
Method: *Grab*

Sample Final Analysis

Date: *4/3/26*
Time: *6:00 PM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/1/26	5:30 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/1/26	5:30 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	4/1/26	5:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	4/1/26	11:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	4/1/26	11:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/1/26	11:15 AM	VH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)