



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-13

Lab# 110

Customer

Facility Name: Gold Fish Swim Club
Address: 160 Lake Dr.
Wexford, PA 15090

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/2/26
Time: 10:10 AM
Method: Grab

Sample Final Analysis

Date: 6/4/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/26 10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/26 10:00 AM	AH	SM 9222B
Standard plate count:	20/ml	200/ml	6/2/26 3:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/2/26 10:10 AM	IS	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/2/26 10:10 AM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/2/26 10:10 AM	IS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor