Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 135

Customer

Facility Name:	*Hampton School District*
Address:	*2929 McCully Rd.* *Allison Park, PA 15101*
Matrix:	*Recreational Water*
Source Type:	*Pool Shallow*

Sample Collection

Date:	*4/8/26*
Time:	1:00 PM
Method:	*Grab*

Sample Final Analysis

Date:	*4/10/26*
Time:	*5:00 PM*
Analyst:	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/8/26	4:57 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/8/26	4:57 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	4/8/26	4:57 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	4/8/26	1:00 PM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	4/8/26	1:00 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/8/26	1:00 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor