Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 133

Customer		**Sample Collection**	
Facility Name:	*Hampton Inn - Uniontown*	*Date:*	*4/27/26*
		Time:	1:05 PM
Address:	*698 West Main Street* *Uniontown, PA 15401*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*4/30/26*
		Time:	*11:30 AM*
Source Type:	*Spa*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/28/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/28/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	4/27/26	5:40 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	4/28/26	12:00 PM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	4/27/26	1:05 PM	SH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	4/27/26	1:05 PM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/27/26	1:05 PM	SH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)