



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-2

Lab# 158

Customer

Facility Name: *Holiday Inn Express*
Address: *181 Finley Rd.*
Belle Vernon, PA 15012

Sample Collection

Date: *5/4/26*
Time: *11:10 AM*
Method: *Grab*

Matrix: *Recreational Water*

Sample Final Analysis

Date: *5/7/26*
Time: *10:00 AM*
Analyst: *AS*

Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/5/26	9:55 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/5/26	9:55 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	5/4/26	5:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/4/26	11:10 AM	SH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	5/4/26	11:10 AM	SH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/4/26	11:10 AM	SH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor