Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-3

Lab# 161

[redacted]

Customer

Facility Name: *Holiday Inn Express*

Address: *10 Landings Dr.*
Harmarville, PA 15238

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *3/24/26*
Time: 7:02 AM
Method: *Grab*

Sample Final Analysis

Date: *3/27/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/25/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/25/26	10:00 AM	SL	SM 9222B
Standard plate count:	120/ml	200/ml	3/24/26	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	3/24/26	7:02 AM	AH	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	3/24/26	7:02 AM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/24/26	7:02 AM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor