



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-15

Lab# 167

Customer

Facility Name: Home 2 Suites
Address: 1401 Cranberry Woods Dr.
Cranberry, PA 16066

Sample Collection

Date: 6/16/26
Time: 12:50 PM
Method: Grab

Sample Final Analysis

Date: 6/18/26
Time: 12:30 PM
Analyst: AS

Matrix: Recreational Water
Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Escherichia Coli:	Absent	Absent	6/17/26 12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/26 12:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/26 6:45 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
---------------------	---------	-----------------	----------------------	---------	--------

Fecal Streptococcus	0/100mls	2/100mls	1/0/00 12:00 AM	0	SM 9230C
---------------------	----------	----------	-----------------	---	----------

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
----------------	---------	-----------------	-----------	---------	--------

pH:	8.0 SU	7.2 - 7.8 SU	6/16/26 12:50 PM	EG	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/26 12:50 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/26 12:50 PM	EG	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)