



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**EOP-3**

**Lab# 2759**

**Customer**

**Facility Name:** *Idlewild and SoakZone*

**Address:** *2574 Rt 30 E*  
*Ligonier, PA 15656*

**Matrix:** *Recreational Water*

**Source Type:** *Wave*

**Sample Collection**

**Date:** *5/20/26*

**Time:** *12:00 PM*

**Method:** *Grab*

**Sample Final Analysis**

**Date:** *5/21/26*

**Time:** *12:00 AM*

**Analyst:** *AS*

| Laboratory Analysis   | Results  | Reporting limit | Incubation Date/Time |         | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 5/20/26              | 4:50 PM | SL      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 5/20/26              | 4:50 PM | SL      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 5/20/26              | 3:12 PM | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 5/20/26   | 12:00 PM | EG      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 5/20/26   | 12:00 PM | EG      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 5/20/26   | 12:00 PM | EG      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor