



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

Extra

Laboratory Analysis Report Lab# 2763

Customer

Facility Name: *Idlewild and SoakZone*

Address: *2574 Rt 30 E
Ligonier, PA 15656*

Matrix: *Recreational Water*

Source Type: *Capt. Kid*

Sample Collection

Date: *5/11/26*

Time: *11:32 AM*

Method: *Grab*

Sample Final Analysis

Date: *5/13/26*

Time: *10:30 AM*

Analyst: *AS*

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/12/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/12/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/11/26	5:07 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/11/26	11:32 AM	JC	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/11/26	11:32 AM	JC	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/11/26	11:32 AM	JC	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor