Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-1

Lab# 196

Customer		***Sample Collection***	
Facility Name:	*Kingley Assoc.*	*Date:*	*4/22/26*
		Time:	9:04 AM
Address:	*6435 Frankstown Ave.*	*Method:*	*Grab*
	Pittsburgh, PA 15206		
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*4/24/26*
		Time:	*5:00 PM*
Source Type:	*Pool - Shallow*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/22/26	4:50 PM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/22/26	4:50 PM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	4/22/26	4:15 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	4/22/26	9:04 AM	SL	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	4/22/26	9:04 AM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/22/26	9:04 AM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor