# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**N-2**

***Lab# 234***

**Customer**

*Facility Name:* *North Allegheny High School*

*Address:* *10375 Perry Hwy.*
*Wexford, PA 15090*

*Matrix:* *Recreational Water*

*Source Type:* *Pool Deep*

**Sample Collection**

*Date:* *4/29/26*
*Time:* 9:40 AM
*Method:* *Grab*

**Sample Final Analysis**

*Date:* *5/1/26*
*Time:* *10:30 AM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 4/30/26 | 10:00 AM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 4/30/26 | 10:00 AM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 4/29/26 | 4:32 PM | SL | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 4/29/26 | 9:40 AM | JC | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 4/29/26 | 9:40 AM | JC | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 4/29/26 | 9:40 AM | JC | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor