Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-2

Lab# 235

Customer		***Sample Collection***	
Facility Name:	*North Allegheny High School*	*Date:*	*3/11/26*
		Time:	9:30 AM
Address:	*10375 Perry Hwy.* *Wexford, PA 15090*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*3/13/26*
		Time:	*5:30 PM*
Source Type:	*Pool Shallow*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/11/26	5:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/11/26	5:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	3/11/26	4:05 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	3/11/26	9:30 AM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	3/11/26	9:30 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/11/26	9:30 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor

Andre Smith, Lead Supervisor