Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 248

[redacted]

Customer

Facility Name: *Passavant Retirement*

Address: *401 S Main St*
Zelienople, PA 16063

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *3/30/26*

Time: 11:30 AM

Method: *Grab*

Sample Final Analysis

Date: *4/2/26*

Time: *12:30 PM*

Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	3/31/26	12:00 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	3/31/26	12:00 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	3/30/26	5:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	3/30/26	11:30 AM	BH	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	3/30/26	11:30 AM	BH	DPD
Turbidity:	1 NTU	1 - 2 NTU	3/30/26	11:30 AM	BH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor