



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

EOP-4

Lab# 2402

Customer

Facility Name: Pgh Golf Club
Address: 5280 Northumberland St.
Pittsburgh, PA 15217

Sample Collection

Date: 5/19/26
Time: 9:40 AM
Method: Grab

Matrix: Recreational Water

Source Type: Pool- Shallow

Sample Final Analysis

Date: 5/21/26
Time: 10:30 AM
Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/20/26	10:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/20/26	10:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	5/19/26	4:30 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	5/19/26	9:40 AM	DW	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	5/19/26	9:40 AM	DW	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/19/26	9:40 AM	DW	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor