



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2403

Customer

Facility Name: *Pgh Golf Club*
Address: *5280 Northumberland St.*
Pittsburgh, PA 15217

Matrix: *Recreational Water*

Source Type: *Baby Pool*

Sample Collection

Date: *6/9/26*
Time: *12:24 PM*
Method: *Grab*

Sample Final Analysis

Date: *6/11/26*
Time: *11:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/26	11:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/26	11:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/26	5:35 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/9/26	12:24 PM	JT	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	6/9/26	12:24 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/26	12:24 PM	JT	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor