# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**Service**

***Lab# 379***

[redacted]

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *PPG Paints Arena* | *Date:* | *3/30/26* |
| | | *Time:* | 12:45 PM |
| *Address:* | *1001 Fifth Ave*<br>*Pittsburgh, PA 15219* | *Method:* | *Grab* |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *4/2/26* |
| | | *Time:* | *11:30 AM* |
| *Source Type:* | *Spa* | *Analyst:* | *AS* |

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 3/31/26 | 11:00 AM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 3/31/26 | 11:00 AM | SL | SM 9222B |
| Standard plate count: | 500/ml | 200/ml | 3/30/26 | 5:30 PM | AS | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 3/31/26 | 1:00 PM | SL | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.2 SU | 7.2 - 7.8 SU | 3/30/26 | 12:45 PM | AG | DPD |
| Chlorine: | 3.2 mg/l | 1.0 - 5.0 mg/l | 3/30/26 | 12:45 PM | AG | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 3/30/26 | 12:45 PM | AG | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)