



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 11**

**Lab# 2758**

**Customer**

Facility Name: Seven Springs Resort

Address: 777 Waterwheel Dr.  
Champion, PA 15622

Matrix: Recreational Water

Source Type: Outdoor Splash Pad

**Sample Collection**

Date: 6/8/26

Time: 11:45 AM

Method: Grab

**Sample Final Analysis**

Date: 6/10/26

Time: 10:30 AM

Analyst: AS

| Accredited Analysis   | Results  | Reporting limit | Incubation | Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|------------|-----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/9/26     | 10:00 AM  | MD      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/9/26     | 10:00 AM  | MD      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/8/26     | 4:09 PM   | AS      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time | Analyst  | Method |        |
|----------------|----------|-----------------|-----------|----------|--------|--------|
| pH:            | 7.6 SU   | 7.2 - 7.8 SU    | 6/8/26    | 11:45 AM | JC     | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 6/8/26    | 11:45 AM | JC     | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/8/26    | 11:45 AM | JC     | Visual |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)