



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665

Lab ID No. 02-04041

W-10

Laboratory Analysis Report Lab# 2744

Customer

Facility Name: Seven Oaks C.C.

Address: 132 Lisbon Road
Beaver, PA 15009

Matrix: Recreational Water

Source Type: Adult Pool

Sample Collection

Date: 6/15/26

Time: 3:18 PM

Method: Grab

Sample Final Analysis

Date: 6/17/26

Time: 12:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/16/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/16/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/15/26	6:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/15/26	3:18 PM	AH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/15/26	3:18 PM	AH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/15/26	3:18 PM	AH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor