# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**C-2**

***Lab# 375***

[redacted]

| ***Customer*** | | ***Sample Collection*** | |
|---|---|---|---|
| *Facility Name:* | *Southside Works* | *Date:* | *4/20/26* |
| | | *Time:* | 2:24 PM |
| *Address:* | *2626 South Tunnel Blvd*<br>*Pittsburgh, PA 15203* | *Method:* | *Grab* |
| | | ***Sample Final Analysis*** | |
| *Matrix:* | *Recreational Water* | *Date:* | *4/23/26* |
| | | *Time:* | *10:00 AM* |
| *Source Type:* | *Spa* | *Analyst:* | *AS* |

| **Accredited Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 4/21/26 | 9:55 AM | AS | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 4/21/26 | 9:55 AM | AS | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 4/20/26 | 5:00 PM | AS | SM 9215B |

| **Additional Analysis** | **Results** | **Reporting limit** | **Incubation Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 4/21/26 | 11:00 AM | AS | SM 9230C |

| **Field Analysis** | **Results** | **Reporting limit** | **Date/Time** | | **Analyst** | **Method** |
|---|---|---|---|---|---|---|
| pH: | 7.4 SU | 7.2 - 7.8 SU | 4/20/26 | 2:24 PM | SL | DPD |
| Chlorine: | 1.0 mg/l | 1.0 - 5.0 mg/l | 4/20/26 | 2:24 PM | SL | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 4/20/26 | 2:24 PM | SL | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)