



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-11

Lab# 375

Customer

Facility Name: Southside Works
Address: 2626 South Tunnel Blvd
Pittsburgh, PA 15203

Sample Collection

Date: 6/15/26
Time: 3:35 PM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 6/17/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/16/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/16/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/15/26	5:50 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/16/26	12:30 PM	AS	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	6/15/26	3:35 PM	JMH	DPD
Chlorine:	0.5 mg/l	1.0 - 5.0 mg/l	6/15/26	3:35 PM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/15/26	3:35 PM	JMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)