



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 408

Customer

Facility Name: Springhill Suites

Address: 125 E. Jefferson St.
Butler, PA 16001

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/5/26

Time: 4:09 PM

Method: Grab

Sample Final Analysis

Date: 5/8/26

Time: 12:00 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/6/26	11:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/6/26	11:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	5/5/26	6:10 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	5/5/26	4:09 PM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/5/26	4:09 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/5/26	4:09 PM	MM	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)