



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**C-11**

**Lab# 286**

**Customer**

**Facility Name:** Spring Hill Suites  
**Address:** 223 Federal St.  
Pittsburgh, PA 15212

**Sample Collection**

**Date:** 6/8/26  
**Time:** 2:29 PM  
**Method:** Grab

**Sample Final Analysis**

**Date:** 6/10/26  
**Time:** 12:30 PM  
**Analyst:** AS

**Matrix:** Recreational Water  
**Source Type:** Pool

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 6/9/26 12:00 PM      | MD      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/9/26 12:00 PM      | MD      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/8/26 7:05 PM       | SL      | SM 9215B |

| Field Analysis | Results   | Reporting limit | Date/Time      | Analyst | Method |
|----------------|-----------|-----------------|----------------|---------|--------|
| pH:            | 7.0 SU    | 7.2 - 7.8 SU    | 6/8/26 2:29 PM | JMH     | DPD    |
| Chlorine:      | 10.0 mg/l | 1.0 - 5.0 mg/l  | 6/8/26 2:29 PM | JMH     | DPD    |
| Turbidity:     | 1 NTU     | 1 - 2 NTU       | 6/8/26 2:29 PM | JMH     | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor