



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-14

Lab# 473

Customer

Facility Name: Summit Athletic Club

Address: 2900 Plane Rd.
Altoona, PA 16617

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/9/26

Time: 2:00 PM

Method: Grab

Sample Final Analysis

Date: 6/11/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/10/26 11:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/26 11:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/26 6:00 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	6/9/26 2:00 PM	DNP	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/26 2:00 PM	DNP	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/26 2:00 PM	DNP	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)