Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E-3

Lab# 474

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Summit Athletic Club*	*Date:*	*4/8/26*
		Time:	12:01 PM
Address:	*2900 Plank Rd.* *Altoona, PA 16601*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*4/10/26*
		Time:	*5:00 PM*
Source Type:	*Spa*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	4/8/26	4:57 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/8/26	4:57 PM	SL	SM 9222B
Standard plate count:	100/ml	200/ml	4/8/26	4:57 PM	SL	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	4/8/26	4:57 PM	SL	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.2 SU	7.2 - 7.8 SU	4/8/26	12:01 PM	SL	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	4/8/26	12:01 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/8/26	12:01 PM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)