



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

E - 10

Lab# 2694

Customer

Facility Name: Village of Totteridge

Address: 121 Chipperfield
Greensburg, PA 15601

Sample Collection

Date: 6/16/26
Time: 2:45 PM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/18/26
Time: 11:30 AM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/26	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/26	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/26	4:50 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/26	2:45 PM	LL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/16/26	2:45 PM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/26	2:45 PM	LL	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)