Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-1

Lab# 322

Customer		***Sample Collection***	
Facility Name:	*Upper St. Clair Rec.*	*Date:*	*4/28/26*
		Time:	1:22 PM
Address:	*1551 Mayview Road* *Upper St. Clair, PA 15241*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*5/1/26*
		Time:	*10:30 AM*
Source Type:	*Spa*	*Analyst:*	*AS*

Accredited Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Escherichia Coli:	Absent	Absent	4/29/26	10:10 AM	AS	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/29/26	10:10 AM	AS	SM 9222B
Standard plate count:	0/ml	200/ml	4/28/26	5:30 PM	AS	SM 9215B

Additional Analysis	**Results**	**Reporting limit**	**Incubation Date/Time**		**Analyst**	**Method**
Fecal Streptococcus	0/100mls	2/100mls	4/29/26	11:00 AM	AS	SM 9230C

Field Analysis	**Results**	**Reporting limit**	**Date/Time**		**Analyst**	**Method**
pH:	7.4 SU	7.2 - 7.8 SU	4/28/26	1:22 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	4/28/26	1:22 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/28/26	1:22 PM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)