



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

C-10

Lab# 2554

Customer

Facility Name: Village of Shadyside

Address: 100 Denniston Ave.
Pittsburgh, Pa 15206

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/16/26

Time: 3:02 PM

Method: Grab

Sample Final Analysis

Date: 6/18/26

Time: 11:30 AM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/26	11:00 AM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/26	11:00 AM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/26	5:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.2 SU	7.2 - 7.8 SU	6/16/26	3:02 PM	JT	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/16/26	3:02 PM	JT	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/26	3:02 PM	JT	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)