Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

S-3

Lab# ***327***

[redacted]

Customer		***Sample Collection***	
Facility Name:	*Washington & Jefferson*	*Date:*	*4/15/26*
		Time:	1:02 PM
Address:	*60 S. Lincoln St.* *Washington, PA 15301*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*4/18/26*
		Time:	*11:00 AM*
Source Type:	*Lap Pool*	*Analyst:*	*AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/16/26	10:30 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/16/26	10:30 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	4/15/26	5:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	4/15/26	1:02 PM	SL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	4/15/26	1:02 PM	SL	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/15/26	1:02 PM	SL	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)