



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

Service

Lab# 340

Customer

Facility Name: Winchester Apts
Address: 540 N. Neville St.
Pittsburgh, PA 15213

Sample Collection

Date: 6/1/26
Time: 11:15 AM
Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Date: 6/3/26
Time: 12:30 PM
Analyst: AS

Source Type: Pool

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/2/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/2/26	12:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/1/26	6:00 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.9 SU	7.2 - 7.8 SU	6/1/26	11:15 AM	AG	DPD
Chlorine:	4.4 mg/l	1.0 - 5.0 mg/l	6/1/26	11:15 AM	AG	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/1/26	11:15 AM	AG	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)