Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N - 1

Lab# 354

[redacted]

Customer		***Sample Collection***	
Facility Name:	*YMCA - Butler*	*Date:*	*4/27/26*
		Time:	4:05 PM
Address:	*339 North Washington St.* *Butler, PA 16001*	*Method:*	*Grab*
		Sample Final Analysis	
Matrix:	*Recreational Water*	*Date:*	*4/30/26*
		Time:	*12:30 PM*
Source Type:	*Small Pool*	*Analyst:*	*1/0/00*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/28/26	12:00 PM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/28/26	12:00 PM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	4/27/26	5:40 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	4/27/26	4:05 PM	MM	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	4/27/26	4:05 PM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/27/26	4:05 PM	MM	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)