



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 364

Customer

Facility Name: YMCA - Sewickley
Address: 625 Blackburn Road
Sewickley, PA 15143

Matrix: Recreational Water
Source Type: Small Pool

Sample Collection

Date: 5/26/26
Time: 12:30 PM
Method: Grab

Sample Final Analysis

Date: 5/28/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/27/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/27/26	10:00 AM	AH	SM 9222B
Standard plate count:	120/ml	200/ml	5/26/26	4:00 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/26/26	12:30 PM	VH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/26/26	12:30 PM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/26/26	12:30 PM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor