



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-1

Lab# 365

Customer

Facility Name: YMCA - Sewickley
Address: 625 Blackburn Rd.
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Spa

Sample Collection

Date: 5/18/26
Time: 11:00 AM
Method: Grab

Sample Final Analysis

Date: 5/20/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	5/19/26 10:00 AM	AH	SM 9222G

Total coliforms:	0/100mls	2/100mls	5/19/26 10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/18/26 5:50 PM	SL	SM 9215B

Additional Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	5/19/26 11:00 AM	JC	SM 9230C

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	5/18/26 11:00 AM	AMH	DPD
Chlorine:	5.0 mg/l	1.0 - 5.0 mg/l	5/18/26 11:00 AM	AMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/18/26 11:00 AM	AMH	Visual

Sample comments

Andre Smith

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)