



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**E - 10**

**Lab# 2616**

**Customer**

**Facility Name:** *Youghiogheny C.C.*  
**Address:** *1901 Greenock Buena Vista Rd.*  
*McKeesport, PA 15135*

**Sample Collection**

**Date:** *5/27/26*  
**Time:** *10:15 AM*  
**Method:** *Grab*

**Matrix:** *Recreational Water*

**Sample Final Analysis**

**Date:** *5/29/26*  
**Time:** *11:30 AM*  
**Analyst:** *AS*

**Source Type:** *Deep End*

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 5/28/26              | 11:00 AM | AH      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 5/28/26              | 11:00 AM | AH      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 5/27/26              | 6:20 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.4 SU   | 7.2 - 7.8 SU    | 5/27/26   | 10:15 AM | LL      | DPD    |
| Chlorine:      | 3.0 mg/l | 1.0 - 5.0 mg/l  | 5/27/26   | 10:15 AM | LL      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 5/27/26   | 10:15 AM | LL      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor