



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

W-12

Lab# 2483

Customer

Facility Name: Sewickley Ridge

Address: 150 Freedom Lane
Sewickley, PA 15143

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 6/3/26
Time: 11:45 AM
Method: Grab

Sample Final Analysis

Date: 6/4/26
Time: 3:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/26	3:15 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/26	3:15 PM	SL	SM 9222B
Standard plate count:	0/ml	200/ml	6/3/26	3:15 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	8.0 SU	7.2 - 7.8 SU	6/3/26	11:45 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/3/26	11:45 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/26	11:45 AM	VH	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor