# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**Lab ID No. 02-04041**

**N - 1**

***Lab# 2635***

[redacted]

***Customer***

*Facility Name:* *Village Cranberry Woods Apt.*

*Address:* *5001 Pendleton Way*
*Cranberry, PA 16066*

*Matrix:* *Recreational Water*

*Source Type:* *Spa*

***Sample Collection***

*Date:* *4/27/26*
*Time:* 9:34 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *4/30/26*
*Time:* *12:30 PM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 4/28/26 | 12:00 PM | JC | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 4/28/26 | 12:00 PM | JC | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 4/27/26 | 5:40 PM | SL | SM 9215B |

| Additional Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Fecal Streptococcus | 0/100mls | 2/100mls | 4/28/26 | 12:00 PM | JC | SM 9230C |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 4/27/26 | 9:34 AM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 4/27/26 | 9:34 AM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 4/27/26 | 9:34 AM | MM | Visual |

**Sample comments**

Andre Smith

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)