



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041
C-11

Lab# 2720

Customer

Facility Name: *Brewer's Block*
Address: *3234 Libery Ave.*
Pittsburgh, PA 15201

Sample Collection

Date: *6/3/26*
Time: *10:30 AM*
Method: *Grab*

Sample Final Analysis

Date: *6/4/26*
Time: *6:30 PM*
Analyst: *AS*

Matrix: *Recreational Water*
Source Type: *Pool*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/3/26	6:20 PM	SL	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/3/26	6:20 PM	SL	SM 9222B
Standard plate count:	110/ml	200/ml	6/3/26	6:20 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	6/3/26	10:30 AM	JB	DPD
Chlorine:	0.0 mg/l	1.0 - 5.0 mg/l	6/3/26	10:30 AM	JB	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/3/26	10:30 AM	JB	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor