



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2543

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: *Valleybrook Swim Club*

Address: *100 Callender Rd*
 Pittsburgh, PA 15237

Sample Collection

Date: *6/16/26*
Time: *2:30 PM*
Method: *Grab*

Matrix: *Recreational Water*

Source Type: *Deep End*

Sample Final Analysis

Date: *6/18/26*
Time: *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/17/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/17/26	10:00 AM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	6/16/26	4:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit		Date/Time	Analyst	Method
pH:	7.6 SU	7.2 - 7.8 SU	6/16/26	2:30 PM	IS	DPD
Chlorine:	2.0 mg/l	1.0 - 5.0 mg/l	6/16/26	2:30 PM	IS	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/16/26	2:30 PM	IS	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor