Lab ID No. 02-04041

# Dream Pools and Spas
## 1105 Washington Blvd
## Pittsburgh, Pennsylvania 15206
## (412) 661- 7665
## Laboratory Analysis Report

**APM**

***Lab#*** ***325***

***Customer***

*Facility Name:* *Virginia Mansions*

*Address:* *2120 Greentree Rd.*
*Pittsburgh, PA 15220*

*Matrix:* *Recreational Water*

*Source Type:* *Pool*

***Sample Collection***

*Date:* *3/30/26*
*Time:* 9:38 AM
*Method:* *Grab*

***Sample Final Analysis***

*Date:* *4/2/26*
*Time:* *12:30 PM*
*Analyst:* *AS*

| Accredited Analysis | Results | Reporting limit | Incubation Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| Escherichia Coli: | Absent | Absent | 3/31/26 | 12:00 PM | SL | SM 9222G |
| Total coliforms: | 0/100mls | 2/100mls | 3/31/26 | 12:00 PM | SL | SM 9222B |
| Standard plate count: | 0/ml | 200/ml | 3/30/26 | 5:30 PM | AS | SM 9215B |

| Field Analysis | Results | Reporting limit | Date/Time | | Analyst | Method |
|---|---|---|---|---|---|---|
| pH: | 7.8 SU | 7.2 - 7.8 SU | 3/30/26 | 9:38 AM | MM | DPD |
| Chlorine: | 3.0 mg/l | 1.0 - 5.0 mg/l | 3/30/26 | 9:38 AM | MM | DPD |
| Turbidity: | 1 NTU | 1 - 2 NTU | 3/30/26 | 9:38 AM | MM | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor