Lab ID No. 02-04041

Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

APM

Lab# ***325***

Customer

Facility Name: *Virginia Mansions*

Address: *2120 Greentree Rd.*
Pittsburgh, PA 15220

Matrix: *Recreational Water*

Source Type: *Pool*

Sample Collection

Date: *4/14/26*
Time: 8:57 AM
Method: *Grab*

Sample Final Analysis

Date: *4/17/26*
Time: *11:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	4/15/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	4/15/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	4/14/26	5:02 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.8 SU	7.2 - 7.8 SU	4/14/26	8:57 AM	MM	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	4/14/26	8:57 AM	MM	DPD
Turbidity:	1 NTU	1 - 2 NTU	4/14/26	8:57 AM	MM	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith

Andre Smith, Lead Supervisor