



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 4**

**Lab# 2608**

**Customer**      *American Pools Management*  
*3261 Babcock Blvd.*  
*Pittsburgh, PA 15237*

*Facility Name:*      *Yards @ 3 Crossings*  
  
*Address:*            *2645 Railroad St.*  
                              *Pittsburgh, PA 15222*

**Sample Collection**

*Date:*                  *6/8/26*  
*Time:*                *9:22 AM*  
*Method:*             *Grab*

*Matrix:*              *Recreational Water*  
  
*Source Type:*      *Spa*

**Sample Final Analysis**

*Date:*                  *6/10/26*  
*Time:*                *12:30 PM*  
*Analyst:*             *AS*

| <b>Accredited Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
|----------------------------|----------------|------------------------|-----------------------------|----------|----------------|---------------|
| Escherichia Coli:          | Absent         | Absent                 | 6/9/26                      | 12:00 PM | MD             | SM 9222G      |
| Total coliforms:           | 0/100mls       | 2/100mls               | 6/9/26                      | 12:00 PM | MD             | SM 9222B      |
| Standard plate count:      | 570/ml         | 200/ml                 | 6/8/26                      | 7:05 PM  | SL             | SM 9215B      |
| <b>Additional Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
| Fecal Streptococcus        | 0/100mls       | 2/100mls               | 6/9/26                      | 12:00 PM | MD             | SM 9230C      |
| <b>Additional Analysis</b> | <b>Results</b> | <b>Reporting limit</b> | <b>Incubation Date/Time</b> |          | <b>Analyst</b> | <b>Method</b> |
| pH:                        | 7.2 SU         | 7.2 - 7.8 SU           | 6/8/26                      | 9:22 AM  | JMH            | DPD           |
| Chlorine:                  | 3.0 mg/l       | 1.0 - 5.0 mg/l         | 6/8/26                      | 9:22 AM  | JMH            | DPD           |
| Turbidity:                 | 1 NTU          | 1 - 2 NTU              | 6/8/26                      | 9:22 AM  | JMH            | Visual        |

**Sample comments**

Andre Smith, Lead Supervisor

( When exceeding reporting limit pool or spa is unfit)