



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 4

Lab# 2608

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Facility Name: Yards @ 3 Crossings
Address: 2645 Railroad St.
Pittsburgh, PA 15222

Sample Collection

Date: 6/15/26
Time: 8:30 AM
Method: Grab

Matrix: Recreational Water
Source Type: Spa

Sample Final Analysis

Date: 6/17/26
Time: 12:30 PM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	6/16/26	12:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/16/26	12:00 PM	AH	SM 9222B
Standard plate count:	150/ml	200/ml	6/15/26	5:50 PM	SL	SM 9215B
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Fecal Streptococcus	0/100mls	2/100mls	6/16/26	12:30 PM	AS	SM 9230C
Additional Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
pH:	7.0 SU	7.2 - 7.8 SU	6/15/26	8:30 AM	JMH	DPD
Chlorine:	1.0 mg/l	1.0 - 5.0 mg/l	6/15/26	8:30 AM	JMH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/15/26	8:30 AM	JMH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)