



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2104

Customer *American Pools Management*
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: *Chestnut Ridge Apt.* *Date:* *6/9/26*
Address: *3200 Chestnut Ridge Dr.* *Time:* *9:15 AM*
Pittsburgh, PA 15205 *Method:* *Grab*

Sample Final Analysis

Matrix: *Recreational Water* *Date:* *6/11/26*
Source Type: *Pool* *Time:* *10:30 AM*
Analyst: *AS*

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
----------------------------	----------------	------------------------	-----------------------------	----------------	---------------

Escherichia Coli:	Absent	Absent	6/10/26 10:00 AM	MD	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/10/26 10:00 AM	MD	SM 9222B
Standard plate count:	0/ml	200/ml	6/9/26 3:30 PM	SL	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
-----------------------	----------------	------------------------	------------------	----------------	---------------

pH:	7.4 SU	7.2 - 7.8 SU	6/9/26 9:15 AM	VH	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/9/26 9:15 AM	VH	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/9/26 9:15 AM	VH	Visual

Sample comments

Andre Smith, Lead Supervisor

(When exceeding reporting limit pool or spa is unfit)