



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 2

Lab# 2130

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Community Swim Club

Date: 5/26/26

Address: 106 Aqua Drive
Pittsburgh, PA 15238

Time: 3:50 PM

Method: Grab

Sample Final Analysis

Matrix: Recreational Water

Date: 5/28/26

Source Type: Baby Pool

Time: 1:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/27/26	1:00 PM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/27/26	1:00 PM	AH	SM 9222B
Standard plate count:	0/ml	200/ml	5/26/26	5:50 PM	SL	SM 9215B
Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	8.0 SU	7.2 - 7.8 SU	5/26/26	3:50 PM	LL	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/26/26	3:50 PM	LL	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/26/26	3:50 PM	LL	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor