



Dream Pools And Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

APM 1

Lab# 2637

Customer

American Pools Management
3261 Babcock Blvd.
Pittsburgh, PA 15237

Sample Collection

Facility Name: Arsenal 201 Phase 1

Date: 6/1/26

Address: 3922 Foster St.
Pittsburgh, PA 15201

Time: 9:45 AM

Method: Grab

Matrix: Recreational Water

Sample Final Analysis

Source Type: Pool 1

Date: 6/3/26

Time: 1:30 PM

Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/2/26	1:00 PM	AH SM 9222G
Total coliforms:	0/100mls	2/100mls	6/2/26	1:00 PM	AH SM 9222B
Standard plate count:	0/ml	200/ml	6/1/26	6:00 PM	SL SM 9215B
Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method
pH:	7.5 SU	7.2 - 7.8 SU	6/1/26	9:45 AM	JH DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	6/1/26	9:45 AM	JH DPD
Turbidity:	1 NTU	1 - 2 NTU	6/1/26	9:45 AM	JH Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor