



**Dream Pools and Spas**  
**1105 Washington Blvd**  
**Pittsburgh, Pennsylvania 15206**  
**(412) 661- 7665**  
**Laboratory Analysis Report**

Lab ID No. 02-04041

**APM 3**

**Lab# 2318**

**Customer**      *American Pools Management*  
3261 Babcock Blvd.  
Pittsburgh, PA 15237

*Facility Name:*      *LaVale*  
*Address:*            *140 Lavale Dr.*  
                              *Monroeville, PA 15146*

**Sample Collection**

*Date:*                  6/2/26  
*Time:*                10:37 AM  
*Method:*            Grab

*Matrix:*              *Recreational Water*  
*Source Type:*      *Pool*

**Sample Final Analysis**

*Date:*                  6/4/26  
*Time:*                12:30 PM  
*Analyst:*             AS

| Accredited Analysis   | Results  | Reporting limit | Incubation Date/Time |          | Analyst | Method   |
|-----------------------|----------|-----------------|----------------------|----------|---------|----------|
| Escherichia Coli:     | Absent   | Absent          | 1/0/00               | 12:00 PM | SL      | SM 9222G |
| Total coliforms:      | 0/100mls | 2/100mls        | 6/3/26               | 12:00 PM | SL      | SM 9222B |
| Standard plate count: | 0/ml     | 200/ml          | 6/2/26               | 7:00 PM  | SL      | SM 9215B |

| Field Analysis | Results  | Reporting limit | Date/Time |          | Analyst | Method |
|----------------|----------|-----------------|-----------|----------|---------|--------|
| pH:            | 7.8 SU   | 7.2 - 7.8 SU    | 6/2/26    | 10:37 AM | DW      | DPD    |
| Chlorine:      | 5.0 mg/l | 1.0 - 5.0 mg/l  | 6/2/26    | 10:37 AM | DW      | DPD    |
| Turbidity:     | 1 NTU    | 1 - 2 NTU       | 6/2/26    | 10:37 AM | DW      | Visual |

**Sample comments**

( When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor