



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

EOP-1

Lab# 2673

Customer

Facility Name: Traditions of America

Address: 507 Rochester Rd.
Cranberry, PA 16066

Matrix: Recreational Water

Source Type: Pool

Sample Collection

Date: 5/18/26

Time: 11:45 AM

Method: Grab

Sample Final Analysis

Date: 5/20/26

Time: 11:30 AM

Analyst: AS

Laboratory Analysis	Results	Reporting limit	Incubation Date/Time		Analyst	Method
Escherichia Coli:	Absent	Absent	5/19/26	11:00 AM	JC	SM 9222G
Total coliforms:	0/100mls	2/100mls	5/19/26	11:00 AM	JC	SM 9222B
Standard plate count:	0/ml	200/ml	5/18/26	5:50 PM	AH	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time		Analyst	Method
pH:	7.4 SU	7.2 - 7.8 SU	5/18/26	11:45 AM	EG	DPD
Chlorine:	3.0 mg/l	1.0 - 5.0 mg/l	5/18/26	11:45 AM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	5/18/26	11:45 AM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor