



Dream Pools and Spas
1105 Washington Blvd
Pittsburgh, Pennsylvania 15206
(412) 661- 7665
Laboratory Analysis Report

Lab ID No. 02-04041

N-14

Lab# 2150

Customer

Facility Name: Deer Run Condo
Address: 200 Central Ln.
Cranberry, PA 16066

Sample Collection

Date: 6/8/26
Time: 12:55 PM
Method: Grab

Sample Final Analysis

Date: 6/10/26
Time: 10:30 AM
Analyst: AS

Accredited Analysis	Results	Reporting limit	Incubation	Date/Time	Analyst	Method
Escherichia Coli:	Absent	Absent	6/9/26	10:00 AM	AH	SM 9222G
Total coliforms:	0/100mls	2/100mls	6/9/26	10:00 AM	0	SM 9222B
Standard plate count:	0/ml	200/ml	6/8/26	4:09 PM	AS	SM 9215B

Field Analysis	Results	Reporting limit	Date/Time	Analyst	Method	
pH:	7.0 SU	7.2 - 7.8 SU	6/8/26	12:55 PM	EG	DPD
Chlorine:	7.5 mg/l	1.0 - 5.0 mg/l	6/8/26	12:55 PM	EG	DPD
Turbidity:	1 NTU	1 - 2 NTU	6/8/26	12:55 PM	EG	Visual

Sample comments

(When exceeding reporting limit pool or spa is unfit)

Andre Smith, Lead Supervisor